

Smoke Detector Test Spray



silicone-free evaporates without leaving residues

Smoke Detector Test Spray is ideal for a secure checking of the correct functioning of optical resp. photoelectrical smoke detectors and smoke switches.

The spray helps to carry out a functional test without agglutinating the electronics. In this way it is guaranteed that the detector or switch work without disruption. The spray does not contain any solid substances and evaporates without leaving residues. Thus the functionality of the devices is in no way affected.

Smoke Detector Test Spray can be used in industrial plants, public facilities and private households. It is safe and easy to apply and gentle with regard to the electronics.

Technical Data

| | |
|-------------------|--|
| Odour | silicone-free evaporates without residues |
| Features | silicone-free, evaporates without residues |
| Storage stability | 24 months |
| Colour | colourless |

Processing

Shake can before use and spray WEICON Smoke Detector Test Spray for about 5 seconds and with a distance of approx. 30 cm towards the smoke detector. If there is no reaction, testing should be repeated. If there is still no reaction after several tests, the smoke detector is defective and must be replaced.

Storage

Pressurized container: protect from sunlight and do not expose to temperatures exceeding +50°C.

Safety and health

When using products, the physical, safety technical, toxicological and ecological data and regulations in our EC safety data sheets must be observed.

Technotopogs FZCO

Head Office Middle East: Hamriya Free Zone-Sharjah, UAE
Tel: +971 6 5262004 • Fax: +971 6 5262030
info@technotopogs.com • www.technotopogs.com

Westhafenplatz 1
60327 Frankfurt/Main, Germany
Tel: +49 (0) 69 710456072